



**2020 MONITORING SCHEDULE as of August 25, 2020**

**Glen Lake community Schools**

**WSSN: 2006545**

This schedule reflects your expected routine monitoring and is subject to change. Send all sample results to the Benzonia Office of the Benzie/Leelanau District Health Department.

Lead/Copper	1/36 months	Between 06/30/2021 & 09/30/2021	003	<ol style="list-style-type: none"> <li>1. Old Boys Locker Rm DF</li> <li>2. Old Girls Locker Rm DF</li> <li>3. HS Girls Locker Rm DF</li> <li>4. HS Boys Locker Rm DF</li> <li>5. 400 Wing Hallway Drinking Fountain</li> <li>6. <del>Band Room Drinking Fountain</del> Room 116</li> <li>7. 300 Wing Hallway Drinking Fountain</li> <li>8. Superintendent Lobby DF</li> <li>9. Elem. Room 127 Drinking Fountain</li> <li>10. Elementary Office Drinking Fountain</li> </ol>
-------------	-------------	--	-----	--

*drinking fountain*

\* The sampling frequency may be reduced to annually if the results are "Not Detected" or the first two sampling events show results reliably and consistently below the MCL  
DF = Drinking Fountain



4125 Cedar Run Rd., Suite B  
 Traverse City, MI 49684  
 Phone 231-946-6767  
 Fax 231-946-8741  
 www.sosanalytical.com

COMPANY: GLEN LAKE COMMUNITY SCHOOLS

SOS PROJECT NO: 215855 - 1  
 SAMPLED BY:: BC

NAME:  
 PROJECT NO:  
 WSSN: 2006545  
 WELL PERMIT:  
 TAX ID:  
 LOCATION: 3375 W BURDICKVILLE RD

DATE RECEIVED: 9/30/2021  
 TIME RECEIVED: 10:25 AM  
 SAMPLE ID: ELEMENTARY - ROOM 116  
 DRINKING FOUNTAIN

MAPLE CITY  
 MI  
 COUNTY: LEELANAU

DATE SAMPLED: 9/30/2021  
 TIME SAMPLED: 7:30 AM  
 SAMPLE MATRIX: DRINKING WATER

TWP:

**METALS**

<u>Analysis</u>	<u>Concentration</u>	<u>LOD</u>	<u>Units</u>	<u>Analyst</u>	<u>Date Completed</u>	<u>Digestion Method</u>	<u>Drinking Water Reg Limit(MCL)</u>
COPPER EPA 200.8	0.26	0.02	mg/L (PPM)	MM	10/6/2021		1.3
LEAD EPA 200.8	ND	0.002	mg/L (PPM)	MM	10/6/2021		0.015

ND = NOT DETECTED  
 LOD = LIMIT OF DETECTION  
 CV = COLD VAPOR ANALYSIS  
 SMCL = FEDERAL NON-ENFORCEABLE LIMIT  
 MCL = MAXIMUM CONTAMINANT LEVEL  
 DISS = DISSOLVED

APPROVED BY: Shanna Shea  
 SHANNA SHEA  
 LAB MANAGER