



**SOS ANALYTICAL**

4125 Cedar Run Road, Suite B  
Traverse City, MI 49684

Phone: (231) 946-6767  
Email: shanna@sosanalytical.com  
www.sosanalytical.com

Fax: (231) 946-8741

**CUSTODY TRANSFER RECORD**

Client / Company Name: Elem HARE School

Site Address: 2006445

Project # / WSSN #:

2006445

Sampling Company:

Sampler's Name: Steve Bluhm/Becca

Send Results To:

Address:

Phone: 231 334 5061

Invoice To:

Address:

SOS Project ID #

**215753**

Cooler Temp (°C) 16.6 Page      of     

**Analysis Information**

HCL		HNO <sub>3</sub>		H <sub>2</sub> SO <sub>4</sub>		NaOH		MEOH	

**RUSH** Due :  
Call To Schedule

**Sample Identification**

**Collection Information**

**# of Containers**

**Matrix**

**Comments / Other Analysis**

Sample Identification	Collection Information Date	Time	# of Containers	Matrix DW, WW, GW, Soil, Oil, Sludge	Comments / Other Analysis	HCL	HNO <sub>3</sub>	H <sub>2</sub> SO <sub>4</sub>	NaOH	MEOH
1- Old Boy Locker Rm	9-27-21	7:05 AM	1	DW		X	X	X	X	X
2- Old Girl's Locker Rm						X	X	X	X	X
3- HS Girl's Locker Rm						X	X	X	X	X
4- HS Boy's Locker Rm						X	X	X	X	X
5- 400 Wing Hallway						X	X	X	X	X
6- 300 Wing Hallway						X	X	X	X	X
7- Superintendents Lobby						X	X	X	X	X
8- Elem Room 127						X	X	X	X	X
9- Elem Office						X	X	X	X	X
10- Elem Office						X	X	X	X	X
11- Elem Office						X	X	X	X	X
12- Elem Office						X	X	X	X	X
13- Elem Office						X	X	X	X	X
14- Elem Office						X	X	X	X	X
15- Elem Office						X	X	X	X	X

Relinquished by: SPORCK Date: 9-27-21 Time:      AM/PM

Received in lab by:      Date:      Time:      AM/PM

Relinquished by:      Date:      Time:      AM/PM

Received in lab by:      Date: 9/27/21 Time: 10:25 AM



4125 Cedar Run Rd., Suite B  
 Traverse City, MI 49684  
 Phone 231-946-6767  
 Fax 231-946-8741  
 www.sosanalytical.com

COMPANY: GLEN LAKE COMMUNITY SCHOOLS

SOS PROJECT NO: 215753

NAME:

SAMPLED BY:: STEVE BLUHM/BECCA

PROJECT NO:

WSSN: 2006545

DATE SAMPLED: 9/27/2021

WELL PERMIT:

TIME SAMPLED: 7:05 AM

TAX ID:

LOCATION: 3375 W BURDICKVILLE

SAMPLE MATRIX: DRINKING WATER

DATE RECEIVED: 9/27/2021

TIME RECEIVED: 10:25 AM

MAPLE CITY

MI

COUNTY:

LEELANAU

TWP:

**METALS**

No:	Analysis	Concentration	LOD	Units	Analyst	Date Completed	Digestion Method	Drinking Water Reg Limit(MCL)
SAMPLE ID: OLD BOY LOCKER RM								
1	COPPER EPA 200.8	0.05	0.02	mg/L (PPM)	SW	10/5/2021		1.3
1	LEAD EPA 200.8	ND	0.002	mg/L (PPM)	SW	10/5/2021		0.015
SAMPLE ID: OLD GIRLS LOCKER RM								
2	COPPER EPA 200.8	0.04	0.02	mg/L (PPM)	SW	10/5/2021		1.3
2	LEAD EPA 200.8	ND	0.002	mg/L (PPM)	SW	10/5/2021		0.015
SAMPLE ID: HS GIRLS LOCKER RM								
3	COPPER EPA 200.8	0.12	0.02	mg/L (PPM)	SW	10/5/2021		1.3
3	LEAD EPA 200.8	ND	0.002	mg/L (PPM)	SW	10/5/2021		0.015
SAMPLE ID: HS BOYS LOCKERS RM								
4	COPPER EPA 200.8	0.14	0.02	mg/L (PPM)	SW	10/5/2021		1.3
4	LEAD EPA 200.8	ND	0.002	mg/L (PPM)	SW	10/5/2021		0.015
SAMPLE ID: 400 WING HALLWAY								
5	COPPER EPA 200.8	0.08	0.02	mg/L (PPM)	SW	10/5/2021		1.3
5	LEAD EPA 200.8	ND	0.002	mg/L (PPM)	SW	10/5/2021		0.015
SAMPLE ID: 300 WING HALLWAY								
6	COPPER EPA 200.8	0.05	0.02	mg/L (PPM)	SW	10/5/2021		1.3
6	LEAD EPA 200.8	ND	0.002	mg/L (PPM)	SW	10/5/2021		0.015

ND = NOT DETECTED

LOD = LIMIT OF DETECTION

CV = COLD VAPOR ANALYSIS

SMCL = FEDERAL NON-ENFORCEABLE LIMIT

MCL = MAXIMUM CONTAMINANT LEVEL

DISS = DISSOLVED

APPROVED BY: Shanna Shea  
 SHANNA SHEA  
 LAB MANAGER



4125 Cedar Run Rd., Suite B  
 Traverse City, MI 49684  
 Phone 231-946-6767  
 Fax 231-946-8741  
 www.sosanalytical.com


COMPANY: GLEN LAKE COMMUNITY SCHOOLS  
 NAME:  
 PROJECT NO:  
 WSSN: 2006545  
 WELL PERMIT:  
 TAX ID:  
 LOCATION: 3375 W BURDICKVILLE  
 MAPLE CITY  
 MI  
 COUNTY: LEELANAU  
 TWP:

SOS PROJECT NO: 215753  
 SAMPLED BY:: STEVE BLUHM/BECCA  
 DATE SAMPLED: 9/27/2021  
 TIME SAMPLED: 7:05 AM  
 SAMPLE MATRIX: DRINKING WATER  
 DATE RECEIVED: 9/27/2021  
 TIME RECEIVED: 10:25 AM

**METALS**

No:	Analysis	Concentration	LOD	Units	Analyst	Date Completed	Digestion Method	Drinking Water Reg Limit(MCL)
SAMPLE ID: SUPERTENENDENTS LOBBY								
7	COPPER EPA 200.8	0.08	0.02	mg/L (PPM)	SW	10/5/2021		1.3
7	LEAD EPA 200.8	ND	0.002	mg/L (PPM)	SW	10/5/2021		0.015
SAMPLE ID: ELEM ROOM 127								
8	COPPER EPA 200.8	0.20	0.02	mg/L (PPM)	SW	10/5/2021		1.3
8	LEAD EPA 200.8	ND	0.002	mg/L (PPM)	SW	10/5/2021		0.015
SAMPLE ID: ELEM OFFICE								
9	COPPER EPA 200.8	0.36	0.02	mg/L (PPM)	SW	10/5/2021		1.3
9	LEAD EPA 200.8	0.006	0.002	mg/L (PPM)	SW	10/5/2021		0.015

ND = NOT DETECTED  
 LOD = LIMIT OF DETECTION  
 CV = COLD VAPOR ANALYSIS  
 SMCL = FEDERAL NON-ENFORCEABLE LIMIT  
 MCL = MAXIMUM CONTAMINANT LEVEL  
 DISS = DISSOLVED

APPROVED BY:   
 SHANNA SHEA  
 LAB MANAGER